



WEST VALLEY REGIONAL FIRE TRAINING
CONSORTIUM

ENGINE COMPANY
STANDARD TRAINING EVOLUTION



EVOLUTION DESCRIPTION

104

PORTABLE MASTER STREAM APPLIANCE

EQUIPMENT PERFORMANCE STANDARD

(1) Engine Co.
Water Supply
Simulated Target
Stopwatch

3 FF COMPANY

4 FF COMPANY

0:00

0:00

PROCEDURE

- TIME STARTS**
1. ENGINE STOPS AT SIMULATED EMERGENCY SCENE
CREW DISMOUNTS APPARATUS
 2. DEPLOY PORTABLE MASTER STREAM APPLIANCE
 3. APPARATUS PROCEEDS TO HYDRANT TO SECURE SUPPLY.
REVERSE LEAD 200' OF HOSE (LDH or 2 x 2 1/2") TO SUPPLY MASTER
STREAM APPLIANCE
 4. APPARATUS SECURES WATER SUPPLY AT HYDRANT

TIME STOPS MASTER STREAM IN OPERATION & OBJECTIVES COMPLETE:

- ADEQUATE FLOW ESTABLISHED TO TARGET AREA (500 GPM)
- WATER SUPPLY IS SECURED
- RELIEF VALVE SET ACCORDING TO DEPARTMENT SOG

DIAGRAM

PORTABLE MASTER STREAM APPLIANCE
(500 GPM)



200' of LDH or Dual 2 1/2"
REVERSE LEAD



SECURE
WATER SUPPLY

REFERENCE

NFPA 1410 : STANDARD ON TRAINING FOR INITIAL EMERGENCY SCENE OPERATIONS
DEPARTMENT / REGIONAL SOGs

A.7.1.1(a)
#