



**WEST VALLEY REGIONAL FIRE TRAINING
CONSORTIUM**



**ENGINE COMPANY
STANDARD TRAINING EVOLUTION**

EVOLUTION DESCRIPTION

201

1 3/4" FIRE ATTACK, 2 - OUT HOSELINE

EQUIPMENT PERFORMANCE STANDARD

(2) Engine Co.
Water Supply
Simulated Target
Stopwatch

3 FF COMPANY

4 FF COMPANY

0:00

0:00

PROCEDURE

ENGINE 1

TIME STARTS

1. E1 STOPS AT HYDRANT
2. E1 FORWARD LEAD (DRY) 200' OF LDH FOR SUPPLY
3. E1 STOPS AT SCENE
4. E1 DEPLOY 1 3/4" PRECONNECT HOSELINE FOR FIRE ATTACK TO TARGET
5. 1 3/4" HOSELINE CHARGED, E1 CREW DON SCBA
6. ESTABLISH STREAM, ADVANCE 50' WHILE FLOWING

ENGINE 2 – 1:00 MINUTE DELAY FROM START OF EVOLUTION

1. E2 SECURES WATER SUPPLY FOR E1
2. E2 DEPLOY 2 – OUT HOSELINE (150 GPM)
3. 2 – OUT HOSELINE CHARGED, E2 CREW DON SCBA

TIME STOPS

HOSE LINES IN OPERATION & OBJECTIVES COMPLETE:

- E1 ADVANCED TO TARGET, ADEQUATE FLOW ESTABLISHED (150 GPM)
- WATER SUPPLY SECURED, RELIEF VALVE SET ACCORDING TO SOGs
- 2 – OUT HOSELINE IN-PLACE, E2 CREW PREPARED FOR ENTRY

DIAGRAM



REFERENCE

NFPA 1410 : STANDARD ON TRAINING FOR INITIAL EMERGENCY SCENE OPERATIONS
DEPARTMENT / REGIONAL SOGs

A.6.1.1(a)
#