



**WEST VALLEY REGIONAL FIRE TRAINING
CONSORTIUM**



**MULTI - COMPANY
STANDARD TRAINING EVOLUTION**

EVOLUTION DESCRIPTION

301

RESIDENTIAL FIRE – Fire Attack, 2-Out, Truck “Split”

EQUIPMENT PERFORMANCE STANDARD

(2) Engine Co.
(1) Truck Co.
Training Structure
Water Supply

3 FF COMPANY

4 FF COMPANY

N/A

N/ A

PROCEDURE

ENGINE 1

TIME STARTS

1. E1 STOPS AT HYDRANT AND PREPARES TO ESTABLISH SUPPLY
2. E1 FORWARD LEAD 200' LDH (DRY) FOR SUPPLY
3. E1 VERBALIZES SIZE-UP OF STRUCTURE, AND INITIATE FIRE ATTACK
4. E1 DEPLOY 150' x 1 3/4" HOSE TO ENTRY POINT OF BUILDING
5. E1 CREW DON SCBA, PREPARE FOR ENTRY WITH CHARGED HOSELINE
6. ESTABLISH STREAM FROM E1 HOSELINE, ADVANCE 50' WHILE FLOWING

ENGINE 2 – 1:00 MINUTE DELAY FROM START OF EVOLUTION

1. E2 ARRIVES ON SCENE AND PREPARES TO SUPPORT E1 FIRE ATTACK.
 - SECURE WATER SUPPLY – “2-OUT” HOSE LINE – ESTABLISH COMMAND
2. E2 SECURE WATER SUPPLY FOR E1
3. E2 DEPLOY SECOND 1 3/4" HOSE LINE AND ESTABLISH 2 – OUT HOSELINE
4. 2 – OUT HOSELINE CHARGED, E2 CREW DON SCBA
5. E2 CAPTAIN ESTABLISHES COMMAND

TRUCK 1 – 2:00 MINUTE DELAY FROM START OF EVOLUTION

1. T1 ARRIVES ON SCENE AND VERBALIZES “SPLIT” OPERATIONAL MODE:
 - INSIDE TEAM – FORCIBLE ENTRY & PRIMARY SEARCH
 - OUTSIDE TEAM – COORDINATED VENTILATION
2. INSIDE TEAM PERFORMS FORCIBLE ENTRY AS NECESSARY.
CONDUCT PRIMARY SEARCH OF FIRE FLOOR OR DESIGNATED AREA.
3. OUTSIDE TEAM PLACES LADDERS & EQUIPMENT FOR VENTILATION.
COORDINATE VENTILATION OPERATIONS WITH INTERIOR CREWS.

TIME STOPS

FIRE ATTACK, 2-OUT HOSE LINE, SEARCH & VENT OBJECTIVES COMPLETE:

- E1 ADVANCED TO TARGET, ADEQUATE FLOW ESTABLISHED (150 GPM)
- WATER SUPPLY SECURED, RELIEF VALVE SET ACCORDING TO SOGs
- 2 – OUT HOSELINE IN-PLACE AND STAFFED BY E2
- T1 (INSIDE TEAM) COMPLETES PRIMARY SEARCH OF DESIGNATED AREA
- T1 (OUTSIDE TEAM) IN POSITION TO PERFORM VENTILATION
- T1 (OUTSIDE TEAM) CONTACTS INTERIOR CREWS – NO VENT CUT PERFORMED

REFERENCE

**NFPA 1410 : STANDARD ON TRAINING FOR INITIAL EMERGENCY SCENE OPERATIONS
DEPARTMENT / REGIONAL SOGs**

#

DIAGRAM

E1 – 200 FT. LDH (DRY)
E2 – SECURE WATER SUPPLY



E1 – 150' x 1 3/4" HOSELINE
(150 GPM MINIMUM)



50 FEET

T1 – "SPLIT"
(SEARCH & VENT)

E2 – SUPPLY, 2 – OUT, & COMMAND

